

- (c) The following are not eligible for registration under this program:
- (1) any engine used to propel mobile equipment or a motor vehicle of any kind;
 - (2) any engine or equipment unit not meeting the definition of portable as defined in section 2452 (z) of this regulation;
 - (3) any equipment unit and its associated engine determined by the Executive Officer to qualify as part of a stationary source permitted by a district;
 - (4) any portable engine or equipment unit subject to an applicable federal Maximum Achievable Control Technology standard, or National Emissions Standard for Hazardous Air Pollutants, or federal New Source Performance Standard, except for equipment units subject to 40 CFR Part 60 Subpart OOO (Standards of Performance for Nonmetallic Mineral Processing Plants);
 - (5) any portable engine or equipment unit operating within the boundaries of the California Outer Continental Shelf (OCS). [Note: This shall not prevent statewide registration of engines and equipment units already permitted by a district for operation in the OCS. Such statewide registration shall only be valid for operation onshore and in State Territorial Waters (STW).];
 - (6) any dredging operation in the Santa Barbara Harbor;
 - (7) any dredging unit owned by a single port authority, harbor district, or similar agency in control of a harbor, and operated only within the same harbor;
 - (8) generators used for power production into the grid, except to maintain grid stability during an emergency event or other unforeseen event that affects grid stability; and
 - (9) generators used to provide primary or supplemental power to a building, facility, stationary source, or stationary equipment, except during unforeseen interruptions of electrical power from the serving utility, maintenance and repair operations, electrical upgrade operations that do not exceed 60 calendar days, operations where the voltage, frequency, or electrical current requirements can only be supplied by a portable generator, or remote operations where grid power is unavailable. For interruptions of electrical power, the operation of a registered generator including startup, shutdown and testing shall not exceed the time of the actual interruption of power.
- (d) Any engine or equipment unit that loses eligibility for registration under this program shall apply for a permit with a district within 90 days of being notified of loss of eligibility. Registration shall remain valid and operation may continue under this article until the district grants or denies approval for the engine or equipment unit.